



FIRE SAFETY CORRECTION NOTICE

FILE NUMBER 18-38-03-0002	P#1	PAGE 1	OF 1	PAGE 1	
NAME San Francisco State University - Creative Arts Building		HOURS	MINUTES		
ADDRESS 1600 Holloway San Francisco, CA.					

THE CALIFORNIA HEALTH AND SAFETY CODE AND THE STATE FIRE MARSHAL'S REGULATIONS REQUIRE THE FOLLOWING FIRE SAFETY DEFICIENCIES BE CORRECTED:

A construction inspection was conducted on this date for the installation of eight inch underground piping for the proposed Creative Arts Building. Underground piping was installed at Font Ave., across the street to the softball field.

Inspection was conducted for thrust blocks at the tie in and found acceptable.

A flush was conducted from the tie in to across the street at the underground line and found acceptable.

The above deficiencies are to be corrected within 0 days. When all deficiencies have been corrected, sign and return a copy of the certification to 602 E. Huntington Dr. Ste. A Monrovia, CA 91016 or P.O. Box 944246, Sacramento, CA 94244-2460. If you have any questions, please contact the Office of the State Fire Marshal at (925) 708-7316.

DATE	SIGNATURE
------	-----------

ISSUED BY (DEPUTY STATE FIRE MARSHAL) April Horvatits	RECEIVED BY Baron Gee	DATE March 30, 2011
---	---------------------------------	-------------------------------